


序号	报告编号	发布日期	结论	影像资料
44	GX-B1358/21-3-24001	2024. 3. 18	所检项目合格。	
45	GX-B1358/21-3-24002	2024. 3. 18	所检项目合格。	

46	GX-B1300/23-3-24003	2024. 3. 20	综合判定：合格	
47	GX-B1404/20-3-24010	2024. 3. 21	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。	

48	GX-B1404/20-3-24011	2024. 3. 21	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。	
49	GX-B1404/20-3-24012	2024. 3. 21	所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。	


50	GX-B1404/20-3-24013	2024. 3. 21	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。</p>			
51	GX-B1404/20-3-24014	2024. 3. 21	<p>所检电网谐波电压总谐波畸变率、各次谐波电压含有率、谐波电流符合 GB/T 14549-1993 《电能质量 公用电网谐波》要求。</p>			
52	GX-B1321/20-3-24253~24259	2024. 3. 18	<p>本次共检电力电缆7条，7条电力电缆所检项目合格。</p>			

53	GX-B1321/20-3-24233~24242	2024. 3. 19	本次共检电力电缆10条，10条电力电缆所检项目合格。 。			
54	GX-B1321/20-3-24243~24252	2024. 3. 19	本次共检电力电缆10条，10条电力电缆所检项目合格。 。			

55	GX-B1321/20-3-24260~24271	2024. 3. 19	本次共检电力电缆12条，12条电力电缆所检项目合格。	
56	GX-B1495/20-3-24319~24329	2024年3月19日	本次共检高压开关设备11台，11台高压开关设备所检项目合格。	

57	GX-B1495/20-3-24330~24340	2024年3月19日	本次共检高压开关设备11台，11台高压开关设备所检项目合格。	
58	GX-B1495/20-3-24378~24388	2024年3月19日	本次共检高压开关设备11台，11台高压开关设备所检项目合格。	

59	GX-B1495/20-3-24417~24430	2024年3月19日	本次共检高压开关设备14台，14台高压开关设备所检项目合格。	
60	GX-B1495/20-3-24341~24348	2024年3月19日	本次共检高压开关设备8台，8台高压开关设备所检项目合格。	

61	GX-B1495/20-3-24356~24370	2024年3月19日	本次共检高压开关设备15台，15台高压开关设备所检项目合格。	
62	GX-B1495/20-3-24371~24377	2024年3月19日	本次共检高压开关设备7台，7台高压开关设备所检项目合格。 。	

63	GX-B1495/20-3-24389~24399	2024年3月19日	本次共检高压开关设备11台，11台高压开关设备所检项目合格。	
64	GX-B1321/20-3-24290~24299	2024年3月19日	本次共检电力电缆10条，10条电力电缆所检项目合格。	

65	GX-B1321/20-3-24300~24307	2024年3月19日	本次共检电力电缆8条，8条电力电缆所检项目合格。	 A photograph showing a worker wearing a red hard hat and a blue jacket with reflective stripes. The worker is standing in a tunnel-like environment, possibly a cable vault, and is inspecting a large red cable. The date stamp '2024.2.28' is visible in the bottom right corner of the image.
66	GX-B1321/20-3-24308~24319	2024年3月19日	本次共检电力电缆12条，12条电力电缆所检项目合格。	 A photograph showing two workers in a room with electrical equipment. One worker in the foreground is wearing a red hard hat and a black jacket, kneeling and inspecting a cable. Another worker in a plaid shirt is standing in the background. The date stamp '2024.2.29' is visible in the bottom right corner of the image.

67	GX-B1328/20-3-24016	2024年3月19日	本次共检携带式接地和接地短路装置13套，13套携带式接地和接地短路装置合格。	
68	GX-B1328/20-3-24017	2024年3月19日	本次共检绝缘胶垫2件，2件绝缘胶垫合格。	

69	GX-B1328/20-3-24015	2024年3月19日	本次共检验 电器13支， 13支验电器 合格。	
70	GX-B1495/20-3-24535~24541	2024年3月19日	本次共检高压 开关设备 7台，7台高压 开关设备所检 项目合格。	

71	GX-B1495/20-3-24542~24549	2024年3月19日	本次共检高压开关设备8台，8台高压开关设备所检项目合格。	
72	GX-B1495/20-3-24550~24555	2024年3月19日	本次共检高压开关设备6台，6台高压开关设备所检项目合格。	

73	GX-B1495/20-3-24556~24561	2024年3月19日	本次共检高压开关设备6台，6台高压开关设备所检项目合格。	
74	GX-B1495/20-3-24562~24569	2024年3月19日	本次共检高压开关设备8台，8台高压开关设备所检项目合格。	

75	GX-B1321/20-3-24232	2024年3月4日	所检项目合格。	
76	GX-B1300/23-3-24002	2024年3月18日	综合判定： 合格。	

77	GX-B1310/21-3-24028	2024年3月18日	符合标准要求。	
78	GX-B1328/20-3-24032	2024年3月18日	本次共检绝缘手套 10只，10只 绝缘手套合格。	

79	GX-B1328/20-3-24033	2024年3月18日	本次共检绝缘鞋10只，10只绝缘鞋合格。	
80	GX-B1328/20-3-24034	2024年3月15日	本次共检绝缘手套20只，20只绝缘手套合格。	
81	GX-B1328/20-3-24035	2024年3月15日	本次共检绝缘鞋20只，20只绝缘鞋合格。	
82	GX-B1328/20-3-24030	2024年3月15日	本次共检绝缘手套4只，4只绝缘手套合格。	
83	GX-B1328/20-3-24031	2024年3月15日	本次共检绝缘鞋4只，4只绝缘鞋合格。	

84	GX-B1328/20-3-24028	2024年3月15日	本次共检绝缘手套2只，2只绝缘手套合格。	
85	GX-B1328/20-3-24029	2024年3月15日	本次共检绝缘鞋2只，2只绝缘鞋合格。	
86	GX-B1310/21-3-24023	2024. 3. 19	符合标准要求。 。	
87	GX-B1427/21-3-24003	2024. 3. 19	符合标准要求。 。	

88	GX-B1310/21-3-24025	2024. 3. 19	未发现超过Φ2mm当量直径的缺陷。	
89	GX-B1428/21-3-24009	2024. 3. 19	无缺陷迹痕显示。	

90	GX-B1495/20-3-24287~24291	2024. 3. 6	本次共检电力电缆10条，10条电力电缆所检项目合格。 。	
----	---------------------------	------------	---------------------------------	---